

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 3225-0751:002 Page 1 of 1

**CATEGORY:** Fire Dampers

**LISTEE:** Safe-Air, 1855 S. 54th, Cicero IL 60804  
Contact: \*Lee Stack (708) 652-9100 Fax (708) 652-9158

**DESIGN:** Model 410 THERMO/GARD. Refer to listee's data sheet for detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** UL label.

**APPROVAL:** Listed as a 1-hour fire-rated damper.

**NOTE:** Leakage rating not evaluated. Refer to CSFM Listing Category 3230 for listed leakage dampers.

\*Rev. 06-16-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **FEBRUARY 3, 2004**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**